

MEMORANDUM

| | | | |
|----------------|---|------------------|-----------|
| Date | 29 th March 2005 | Reference | |
| To | | | |
| From | Gary Channells | Telephone | 3247 8156 |
| Subject | Test Results for Perimeter Protection Pty Ltd | | |

This is just to confirm that the test carried out for Perimeter Protection was performed under the following conditions and produced the following results.

- The test was performed at the Live Fire Pad, Whyte Island Training Academy.
- The product being tested was a sprinkler system for domestic use in rural and semi-rural areas. It is installed in the existing guttering of properties.
- The product was set up at a distance of 2m from the heat source.
- The product was subjected to the heat for 25 minutes.
- The product was subjected to temperatures up to 600'C.
- The product did not fail at any time during the test.

The actual temperature readouts have been forwarded to Ray Lunt, of the above company, as per his request.



Queensland Fire and Rescue Service

Training and Emergency Management

PO Box 1425, Brisbane Qld 4001

Telephone: 07 3895 6600 Fax: 07 3895 6601

ABN 93035163778

1 April 2005

From Gary Channells

Test Results for Perimeter Protection Pty Ltd

This is just to confirm that the test carried out for Perimeter Protection was performed under the following conditions and produced the following results.

- The test was performed at the Live Fire Pad, Whyte Island Training Academy.
- The product being tested was a sprinkler system for domestic use in rural and semi-rural areas. It is installed in the existing guttering of properties.
- The product was set up at a distance of 2m from the heat source.
- The product was subjected to the heat for 25 minutes.
- The product was subjected to temperatures up to 600°C.
- The product did not fail at any time during the test.

The actual temperature readouts have been forwarded to Ray Lunt, of the above company, as per his request.

A handwritten signature in black ink, appearing to read 'Aerron Patterson'.

Aerron Patterson

A/Branch Manager

QFRS Training and Emergency Management



UNITED FIREFIGHTERS UNION OF AUSTRALIA
UNION OF EMPLOYEES QUEENSLAND

27 February 2003

misc1224/mw

TO WHOM IT MAY CONCERN

This letter serves to confirm that the United Firefighters Union (UFU) has viewed the operation of the "*Perimeter Protection System*".

The UFU gives its endorsement of the concept of this type of product, believing that a product of this type will assist in the protection of properties from the onset of fire particularly in rural/urban interface bushfire prone areas.

I can be contacted on the number below if clarification is needed.

Yours faithfully

A handwritten signature in black ink, appearing to read 'M Walker', written over a white background.

MARK WALKER
State Secretary

United Firefighters' Union - helping firefighters help you

A.B.N. 97 709 271 604

ufu@ufuq.asn.au